

# PROJECT SHOWING QUESTION AND ANSWER DETAILS

Project Number	Project Subaccount Number	Showing Date	Region
STE C040-050	21689		02

Resident Engineer	Project Engineer
David Watt	Yun Han
Others In Attendance:	
Eric Poling-CDOT	Yanni Skaroulis-SouthernRB

It is the responsibility of the bidder to verify all information within this document. If bidders use this information in preparing a proposal, it is used at their own risk. Bidders are responsible for all conclusions, deductions, and inferences drawn from such information.

Source of Question:

Southern RB

Question:

Reduction in working time from 40 to 20 working days?

CDOT Response

This was done to facilitate a quick completion of the project, 20 days being assumed to be more than adequate time to complete the painting of the bridge.

Source of Question:

Southern RB

Question:

Intended method for surface preparation?

CDOT Response

As provided in the plans the intended method would be power washing the structure. The contractor should endeavor not to damage the existing concrete surface of the bridge. If the surface is damaged, it will need to be repaired before the appropriate paint is applied.

## PROJECT SHOWING QUESTION AND ANSWER DETAILS

PAGE: 2

It is the responsibility of the bidder to verify all information within this document. If bidders use this information in preparing a proposal, it is used at their own risk. Bidders are responsible for all conclusions, deductions, and inferences drawn from such information.

Source of Question:

Southern RB

Question:

Runoff filtered or removed entirely?

CDOT Response

The contractor will need to capture and remove the waste from the site.

Source of Question:

Southern RB

Question:

Is the contractor permitted to close the park and parking lot?

CDOT Response

This is not something CDOT may give permission to do. Our IGA permits us access to the park for the purpose of the work, and we may close the area that exists within CDOT ROW, but in order to close the parking lot and park itself, the contractor or CDOT will need to obtain permission from El Paso County as both exist within their ROW.

Source of Question:

Southern RB

Question:

Was the project assumed to be constructed from lift or from stream crossing?

CDOT Response

CDOT did not determine a specific method to access the structure to apply the coating. CDOT has provided and has obtained a USACE permit for a temporary stream crossing of Fountain Creek.